	•		KK
Notice of Allowability	Application No.	Applicant(s)	7.1/=
	10/615,930	GILBERT ET AL.	
	Examiner	Art Unit	
	André K. Jackson	2856	
The MAILING DATE of this communication app All claims being allowable, PROSECUTION ON THE MERITS IS herewith (or previously mailed), a Notice of Allowance (PTOL-85 NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT R of the Office or upon petition by the applicant. See 37 CFR 1.313	(OR REMAINS) CLOSED in this app) or other appropriate communication (IGHTS. This application is subject to	olication. If not include will be mailed in due	ed course. THIS
1. This communication is responsive to the application filed of	on 07/10/03.		
2. The allowed claim(s) is/are <u>1-17</u> .			
3. The drawings filed on 10 July 2003 are accepted by the E	xaminer.		
 4. ☐ Acknowledgment is made of a claim for foreign priority u a) ☐ All b) ☐ Some* c) ☐ None of the: 1. ☐ Certified copies of the priority documents have 2. ☐ Certified copies of the priority documents have 3. ☐ Copies of the certified copies of the priority documents have International Bureau (PCT Rule 17.2(a)). 	e been received. e been received in Application No		tion from the
* Certified copies not received:	· ·	•	
Applicant has THREE MONTHS FROM THE "MAILING DATE" noted below. Failure to timely comply will result in ABANDONN THIS THREE-MONTH PERIOD IS NOT EXTENDABLE. 5. A SUBSTITUTE OATH OR DECLARATION must be subm	MENT of this application.		
INFORMAL PATENT APPLICATION (PTO-152) which giv	es reason(s) why the oath or declara	tion is deficient.	
6. CORRECTED DRAWINGS (as "replacement sheets") mu			
(a) including changes required by the Notice of Draftspers	· ·	948) attached	
 1) ☐ hereto or 2) ☐ to Paper No./Mail Date (b) ☐ including changes required by the attached Examiner 		office action of	
Paper No./Mail Date	3 Amendment 7 dominent of in the c	ince action of	
Identifying indicia such as the application number (see 37 CFR teach sheet. Replacement sheet(s) should be labeled as such in			back) of
 DEPOSIT OF and/or INFORMATION about the deposit attached Examiner's comment regarding REQUIREMENT 	osit of BIOLOGICAL MATERIAL n FOR THE DEPOSIT OF BIOLOGICA	nust be submitted. I AL MATERIAL.	Note the
Attachment(s) 1. ⊠ Notice of References Cited (PTO-892)	5. Notice of Informal P	atent Application (PT)	O-152)
2. ☐ Notice of Draftperson's Patent Drawing Review (PTO-948)	6. ☐ Interview Summary	(PTO-413),	<i>3</i> 10=7
3. Hinformation Disclosure Statements (PTO-1449 or PTO/SB/	•	nent/Comment	
 Examiner's Comment Regarding Requirement for Deposit of Biological Material 	 8. ☑ Examiner's Stateme 9. ☐ Other 	ent of Reasons for Alic	owance
or biological Material	o. <u></u> .		

Application/Control Number: 10/615,930

Art Unit: 2856

EXAMINER'S AMENDMENT

1. The following is an examiner's statement of reasons for allowance: the closest prior art found and relied upon did not disclose a" test tap adapter providing measurements in a transformer bushing and arranged for extracting samples of gases dissolved in insulating oil present in the transformer bushing so as to determine presence of the gases in the insulating oil, the test tap adapter including a tap connector, a tubular runway axially disposed in the tap connector and having a portion extending outside the tap connector, the portion constructed to penetrate into the transformer bushing and to soak in the insulating oil, an insulated conductor mounted in the tubular runway along entire length thereof and having a free length for connection to a conductor provided in the transformer bushing, means for connecting an end of the insulated conductor opposite the free length to an electrical measurement means, and means for anchoring the test tap adapter to the transformer bushing through an opening provided therein, with the outside portion of the tubular runway inside the transformer bushing in contact with the insulating oil, wherein the test tap adapter additionally comprises a gas diffusing member of nonconductive material mounted over the outside portion of the tubular runway, gas permeable but liquid impermeable means covering the gas diffusing member and arranged to allow permeation of gases that may be present in the insulating oil towards the gas diffusing member, gas storage chamber linked to the tap connector, in operative contact with the gas diffusing member and means to allow passive diffusion of

Page 2

Application/Control Number: 10/615,930 Page 3

Art Unit: 2856

permeated gases present in the gas diffusing member towards the gas storage chamber for determining the presence of gases in the insulating oil." In the examiner's opinion it would not have been obvious to modify the prior art to include these limitations.

- 2. Any comments considered necessary by applicant must be submitted no later than the payment of the issue fee and, to avoid processing delays, should preferably accompany the issue fee. Such submissions should be clearly labeled "Comments on Statement of Reasons for Allowance."
- Any inquiry concerning this communication or earlier communications from the examiner should be directed to André K. Jackson whose telephone number is (571) 272-2196. The examiner can normally be reached on Mon.-Thurs. 7AM-4PM.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Hezron Williams can be reached on (571) 272-2208. The fax phone number for the organization where this application or proceeding is assigned is 703-872-9306.

Application/Control Number: 10/615,930

Art Unit: 2856

Page 4

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see http://pair-direct.uspto.gov. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free).

A.J. (A)

January 24, 2005

HEZRÓN WILLIAMS

SUPERVISORY PATENT EXAMINER

TECHNOLOGY CENTER 2800